



NOTES:

- 1) METER SETTER SHALL BE OFFSET HIGH-BY-PASS
- 2) PRIOR TO INSTALLATION CONTACT CITY REP FOR CONFIRMATION OF FLANGE TO FLANGE DIMENSION.
- 3) METER SETTER SHALL BE CENTERED IN BOX
- 4) METER SETTER SHALL BE PLACED IN A MANNER THAT THE HIGH BY PASS IS SET PARALLEL TO THE BOX

CITY OF CORVALLIS

ENGINEERING DIVISION

METER SETTER DETAIL
FOR 2" DOMESTIC METER

DATE: JANUARY, 2003

SCALE: NONE

STANDARD DETAIL No.

APPROVED:

306A